

**SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. 843.....


Date : 15/12/2023.....

It is certified that an inspection team headed by the authorized officer of public Health Department visited the premises of The Vivekanand Vidya Vihar, Maral Overseas Ltd. Khalbujurg, Dist. Khargone and found that the school has safe drinking water facilities for the students and members of staff of the institution and maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for period of three years from the date of issue.



Signature with Seal



Name: Rashmi Senani.....

Designation: Sub. Engineer.....

To,
The Principal
Vivekanand Vidya Vihar, Maral Sarovar
Khalbujurg, P.O. Nimrani, Dist. - Khargone



**Sub Division Laboratory
Public Health Engineering Department Sub Division Kasrawad**

ANALYSIS REPORT

Type of sample :- R.O. Water school campus
 PARTICULARS OF SENDER :- Principal, Vivekanand Vidya Vihar, Maral Sarovar (M.P.)
 Samples Collected by :- Not Collected by Laboratory.
Khat bijurg, P.O. Himrani

Sample No. Place of collection and details of samples			
1	Village - <u>Maral School campus</u>	<input checked="" type="checkbox"/>	Village - <u>-</u>
-	Village - <u>P.O. Water</u>	<input checked="" type="checkbox"/>	Village - <u>-</u>
-	Village - <u>-</u>	<input checked="" type="checkbox"/>	Village - <u>-</u>

PARTICULARS TO BE FILLED IN THE LABORATORY
 Date of Receipt :- 11/12/2023 Tested on :- 11/12/2023

NATURE OF STUDY - CHEMICAL & BACTERIOLOGICAL ANALYSIS

Characteristics	Unit	As Per BIS - 10500:2012 For Drinking Water		Results					
		Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source	Sample 1	Sample 2	Sample 3	Sample 4	Sample 5	Sample 6

PHYSICAL TESTS


1	Colour	Hazen	5.0	15.0	<u>Nil</u>	-	-	-	-	-
2	Turbidity	NTU	1.0	5.0	<u>0.0</u>	-	-	-	-	-

CHEMICAL TESTS


3	pH	pH scale	6.5 to 8.5	No Relaxation	<u>7.00</u>	-	-	-	-	-
4	Conductivity	micromhos per cm	-	-	<u>176</u>	-	-	-	-	-
5	Total Hardness as CaCO ₃	mg/l	200	600	<u>250</u>	-	-	-	-	-
6	Arsenic as As	mg/l	0.01	0.01	<u>0.0</u>	-	-	-	-	-
7	Magnese as Mn	mg/l	0.1	0.3	<u>0.0</u>	-	-	-	-	-
8	Total Alkalinity as CaCO ₃	mg/l	200	600	<u>150</u>	-	-	-	-	-
9	Chloride as Cl	mg/l	250	1000	<u>40</u>	-	-	-	-	-
10	Nitrate as NO ₃	mg/l	45	45	<u>0.0</u>	-	-	-	-	-
11	Total Dissolved Solids	mg/l	500	2000	<u>114</u>	-	-	-	-	-
12	Iron as Fe	mg/l	1.0	1.0	<u>0.0</u>	-	-	-	-	-
13	Sulphate as SO ₄	mg/l	200	400	<u>-</u>	-	-	-	-	-
14	Fluoride as F	mg/l	1.0	1.5	<u>-</u>	-	-	-	-	-
15	Free Residual Chlorine	mg/l	0.2	1.0	<u>0.2</u>	-	-	-	-	-

BACTERIOLOGICAL TESTS

16	Total Coliform	Per 100 ml	Nil	<u>Nil</u>	-	-	-	-	-
17	Thermotolerant Coliform	Per 100 ml	Nil	<u>Nil</u>	-	-	-	-	-


Signature of Analyst

Remarks - -


 Lab. Incharge
 (Authorised Signatory)
 Sub Division Laboratory
 Public Health Engineering Department
 Sub Division Kasrawad
 Date- 12/12/2023

कार्यालय सहायक यंत्री

लोक स्वास्थ्य यांत्रिकीय उपखण्ड-कसरगवद (म.प्र.)

पत्र क्रमांक 818

/प्रयोगशाला/ ला रवा गा. / कसरगवद

दिनांक 07/12/2023

प्रति,

प्राचार्य

विवेकानंद विद्या विहार मराल सरोवर (म.प्र.)

अलनपुरगी पो. निगरानी

विषय :-


पेयजल नमूना के परीक्षण हेतु प्रोफार्मा विल भेजने का बंद।

संदर्भ :- आपका पत्र दिनांक 05/12/2023

—00—

उपरोक्त संदर्भित विषयान्तर्गत लेख है कि आपके द्वारा भेजे गए जल नमूना के भौतिक, रासायनिक एवं जीवाणु परीक्षण हेतु जोच शुल्क का प्रोफार्मा विल रु. 1550.00 (एड इमार पांच सौ पचास मात्र) का तैयार कर प्रेषित है। कृपया भुगतान ट्रेजरी आनलाईन के माध्यम से मद मेजर हेड - 0215-01-800 अन्य प्राप्तियां तथा डिटेल्ड हेड 0165— लोक स्वास्थ्य इंजीनियरींग सेवार्यें लोक स्वास्थ्य यांत्रिकीय को प्रेषित करने का कष्ट करे।

संतान :- प्रोफार्मा विल



सहायक यंत्री,

लोक स्वा. यां. उपखण्ड, कसरगवद

Proforma Bill For Water Samples

to,

The Principal
Vivekanand Vidya Vihar
Maral Sarovar (M.P.)
Khalbujurg P.O. Nimranj
Subject:- Water Sample Testing Charges.

S.No.	Particulars	Rate	No.Of Samples	Total Amount
1.	Turbidity			
2.	Colour			
3.	Chloride as Cl			
4.	pH Value			
5.	Total Hardness			
6.	Iron	1200.00	1 Nos.	1200 .00
7.	Fluoride	Per		
8.	Residual Chlorine Cl ₂	Sample		
9.	TDS			
10.	Nitrate			
11.	Manganese			
12.	Bacteriological Test	350.00 Per Sample	1 No.	350 .00
Total Rs.				1550 .00

Rs. In Words- one thousand
five hundred
fifty only.

22



Assistant Engineer
P.H.E. Sub Division Kasrawad

कार्यालय सहायक यंत्री

लोक स्वास्थ्य यांत्रिकीय उपखण्ड-कसरावद (म.प्र.)

पत्र क्रमांक 832 /प्रयोगशाळा/ लो. स्वा. यां./ कसरावद_दिनांक 14/12/2023

प्रति,

प्राचार्य


विवेकानंद विद्या विहार मंगल सोवर (म.प्र.)

विषय :- जल स्रोत के नमूना की जल परीक्षण रिपोर्ट वाचद।

संदर्भ:- आज्ञा पत्र दिनांक- 05/12/2023
---00---

उपरोक्त संदर्भित विषयान्तर्गत लेख है कि आपके द्वारा प्रेशित जल स्रोत के जल नमूना का भौतिक रासायनिक एवं जीवाणु परीक्षण कर जल परीक्षण रिपोर्ट आपकी ओर प्रेषित है।

संलग्न :-जल परीक्षण रिपोर्ट।


सहायक यंत्री,
लोक स्वा. यां. उपखण्ड, कसरा